SRI BAALAMURUGAN BOREWELLS

4, gangamma Compound, Opp. Canara Bank Bus Stop, Bellary Main Road, Helbal Bangalore - 24
Mob : 9845020536, 9901920004

WORK REPORT

No.

Date : 29-04-15.

Basava Lingappa Nagara

S.No.	Particulars	Rft :	Water Yield	Remarks
1.	Size of The Borewell	165 mm		
2.	Total Deapth of The Borewell	980'		
3.	MS Casing Erected	147'		
4.	1st Water Source at the Deapth	290'		
5.	2nd Water Source at the Deapth	495'		
6.	3rd Water Source at the Deapth	720'		
7.	4th Water Source at the Deapth	910'		
8.	If any Silt, Boulders at the Deapth	-		
9.	Nature of Water	Sweet water		
10.	Moter Pump to be Used	15 HP 3 Stage		
11.	Any other Remarks	-		
12.	Total Yield of the Borewell	2'.6"		

Thanking You

Yours faithfully
For Sri Baalamurugan Borewells

GROUND WATER SURVEY REPORT

~~OPEN WELL~~/ BOREWELL
DATA OF SURVEY

a) Name of the Party : BBMP

b) Location of the Site : AKE Byatarayanapura 8ne Divn

c) Area of the land : Basava Linga Pla Nagara.

INVESTIGATION REPORT

1) GEOLOGY OF THE AREA : hw lyng, Sedpmc, Mudday Bed / gneiss

2) Recommended Site for drilling : W1

3) Total depth to be drilled : 800'-900'

4) Approx. casing pipe required : 120'-130'

5) No. of water bearing Zones : — 5 —

6) No. of favourable spots marked : — 1 —

7) Qty. of water expected : 2 1/2"-3"

8) Method of survey carried out : Gw - Indirect method

9) Remarks : 6 1/2" dia drill at W1

Water source below 140'-850'

P.T.O. : *Terms & Conditions*

HYDROGEOLOGIST
(M.G. RAJASHEKHAR, M.Sc., DEG., F.G.S.)

BOREWELL SITE PLAN



Name of work:- Drilling of borewell and Providing Pump & motor
Ward No-5 Byatarayanapura Sub division

W.No 5. ಬಸವಲಿಂಗಪ್ಪ. ಬಡಾವಣೆ. ಬೆಗೂರ್.

AE-05

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬಾಣಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore

W. No. 5 ಬನಿಚಲಿಂಗಪ್ಪ ಲೇಔಟ್ ಟ್ರಾನ್ಸ್‌ಫಾರ್ಮರ್ ಸ್ಥಳ

ಸಹಾಯಕ ಅಭಿಯಂತರರು
ಬಿ.ಬಿ.ಎಂ.ಪಿ. ಬ್ಯಾಟರಾಯನಪುರ ಉಪ ವಿಭಾಗ

Assistant Executive Engineer
Byatarayanapura Sub Division
B.B.M.P Bangalore